

FECHA: 24-10-2019

CERTIFICADO DE ANALISIS ANTRACITA

Nombre : Antracita, Medio Filtrante	Fecha producción : 23/10/2019
N° Cas : 05-10-8029	Fecha Vencimiento : Sin vencimiento
Lote Producción : HN2019102301	Método de análisis : Estándar CJ/T 44-1999

Parámetro	Especificación	Análisis Típico
Contenido de carbono (basado en análisis de cenizas / sin humedad)	≥ 92 %	93 %
Densidad a Granel	690 ± 50	695
Dureza	≥ 95 %	95 %
Humedad	≤ 5%	4,5 %
Contenido de cenizas	≤ 10 %	9,5 %
Solubilidad ácida	≤ 2 %	1,97 %
Solubilidad en aguas alcalinas	≤ 2 %	1,98 %
Tamaño efectivo	1,2 – 1,4 mm	1,2 – 1,4 mm
Tamaño de malla	8 – 18 mesh	8 – 18, 90% pasa

The present information is only to offer an orientation of the specific characteristics of the product delivered by Mercator Group. We recommend that buyers, when using our products, perform preliminary tests to determine that the characteristics of the product are suitable for their particular purposes. No authorization or guarantee is expressed or implied, with respect to the data. Nothing herein published constitutes a permit, suggestion or recommendation to put into practice inventions protected by any patent, nor as a recommendation for the use of any product or practice any procedure in violation of the law or government regulation, therefore it should not have responsibility awarded to Mercator Group once delivery is made.